



City of Rancho Palos Verdes
Rancho Palos Verdes ADA Assessment
Compliance Report
Facility ID # Area 4 Pedestrian Signals



Reporting: 150 of 4367 Rclds

Author: Vaish, B

Group 04 - Curb Ramps

#	Location	Item Name	Description	1991 ADAAG	2004 ADAAG	2007 CBC	2005 PROWA	Existing Condition	Use	Severity	Location Type
1	Crestridge Rd. & Crenshaw Blvd.	04.24A - Audible Signal Device	A crosswalk with pedestrian signal indication does not have an audible signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	A - Safety Hazard	1 - Access into Facilities (28 CFR 36.304(c)(1))
2	Crestridge Rd. & Crenshaw Blvd.	04.32C - Push Button Size	The pedestrian signal push button is not a min.. 2" across in one dimension.	-	-	-	2005 PROWA G- R306.3.3	1/2" diameter.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
3	Crestridge Rd. & Crenshaw Blvd.	04.33A - Directional Information and Signs	Pedestrian signal device does not provides compliant tactile or visual signs on the face of the device or its housing or mounting to indicate crosswalk direction and the name of the street containing the crosswalk served by the pedestrian signal.	4.30.4	703.1	1117B.5 .1 item 2; 1117B.5 .6	2005 PROWA G- R306.4		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
4	Crestridge Rd. & Crenshaw Blvd.	04.33B - Arrow	Pedestrian signal device does not includes a tactile arrow that contrasts with the background and is aligned parallel to the crosswalk direction.	-	-	-	2005 PROWA G- R306.4.1		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
5	Crestridge Rd. & Crenshaw Blvd.	04.33C - Street Name	Pedestrian signal device does not includes street name information consisting of California Grade 2 Braille and aligned parallel to the crosswalk direction. OR Pedestrian signal device does not provide street name information in audible format. (Street name information in one format or the other is required to be compliant.)	-	-	-	2005 PROWA G- R306.4.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))



City of Rancho Palos Verdes
Rancho Palos Verdes ADA Assessment
Compliance Report



Reporting: 150 of 4367 Rcds

Facility ID # Area 4 Pedestrian Signals

Author: Vaish, B

Group 04 - Curb Ramps

#	Location	Item Name	Description	1991 ADAAG	2004 ADAAG	2007 CBC	2005 PROWA	Existing Condition	Use	Severity	Location Type
6	Crestridge Rd. & Crenshaw Blvd.	04.25 - Pedestrian Signal Device - Clear Floor Space	Location of pedestrian signal device does not accommodate a level 30" x 48" min.. clear space, centered and parallel to the pedestrian signal push button. (Accessible pedestrian signals shall be located so that the vibrotactile feature can be contacted from the level landing serving a curb ramp, if provided, or from a clear floor or ground space that is in line with the crosswalk line adjacent to the vehicle stop line.)	4.2.4	305.3; 305.3	1118B.4 item 1	2005 PROWA G- R306.2.1		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
7	Crestridge Rd. & Crenshaw Blvd.	04.24B - Vibrotactile Signal Device	A crosswalk with pedestrian signal indication does not have a vibrotactile signal device integrated into the signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
8	Crestridge Rd. & Crenshaw Blvd.	04.40 - Other - Curb Ramps and Pedestrian Crossings	See Additional Comments	-	-	-	-		PV - Public/Visitor Use	B - Severe or Complete Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
9	Crestridge Rd. & Crenshaw Blvd.	04.25 - Pedestrian Signal Device - Clear Floor Space	Location of pedestrian signal device does not accommodate a level 30" x 48" min.. clear space, centered and parallel to the pedestrian signal push button. (Accessible pedestrian signals shall be located so that the vibrotactile feature can be contacted from the level landing serving a curb ramp, if provided, or from a clear floor or ground space that is in line with the crosswalk line adjacent to the vehicle stop line.)	4.2.4	305.3; 305.3	1118B.4 item 1	2005 PROWA G- R306.2.1	3.4% RS.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
10	Crestridge Rd. & Crenshaw Blvd.	04.24A - Audible Signal Device	A crosswalk with pedestrian signal indication does not have an audible signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	A - Safety Hazard	1 - Access into Facilities (28 CFR 36.304(c)(1))



City of Rancho Palos Verdes
Rancho Palos Verdes ADA Assessment
Compliance Report



Reporting: 150 of 4367 Rcds

Facility ID # Area 4 Pedestrian Signals

Author: Vaish, B

Group 04 - Curb Ramps

#	Location	Item Name	Description	1991 ADAAG	2004 ADAAG	2007 CBC	2005 PROWA	Existing Condition	Use	Severity	Location Type
11	Crestridge Rd. & Crenshaw Blvd.	04.24B - Vibrotactile Signal Device	A crosswalk with pedestrian signal indication does not have a vibrotactile signal device integrated into the signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
12	Highridge Rd. & Crest Rd.	04.24A - Audible Signal Device	A crosswalk with pedestrian signal indication does not have an audible signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
13	Crestridge Rd. & Crenshaw Blvd.	04.32B - Push Button Locator Tone	The pedestrian signal push button does not incorporate a locator tone at the push button.	-	-	-	2005 PROWA G- R306.3.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
14	Crestridge Rd. & Crenshaw Blvd.	04.32C - Push Button Size	The pedestrian signal push button is not a min.. 2" across in one dimension.	-	-	-	2005 PROWA G- R306.3.3	1/2" diameter.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
15	Crestridge Rd. & Crenshaw Blvd.	04.33A - Directional Information and Signs	Pedestrian signal device does not provides compliant tactile or visual signs on the face of the device or its housing or mounting to indicate crosswalk direction and the name of the street containing the crosswalk served by the pedestrian signal.	4.30.4	703.1	1117B.5 .1 item 2; 1117B.5 .6	2005 PROWA G- R306.4		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
16	Crestridge Rd. & Crenshaw Blvd.	04.33B - Arrow	Pedestrian signal device does not includes a tactile arrow that contrasts with the background and is aligned parallel to the crosswalk direction.	-	-	-	2005 PROWA G- R306.4.1		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))



City of Rancho Palos Verdes
Rancho Palos Verdes ADA Assessment
Compliance Report



Reporting: 150 of 4367 Rcds

Facility ID # Area 4 Pedestrian Signals

Author: Vaish, B

Group 04 - Curb Ramps

#	Location	Item Name	Description	1991 ADAAG	2004 ADAAG	2007 CBC	2005 PROWA	Existing Condition	Use	Severity	Location Type
17	Crestridge Rd. & Crenshaw Blvd.	04.33C - Street Name	Pedestrian signal device does not includes street name information consisting of California Grade 2 Braille and aligned parallel to the crosswalk direction. OR Pedestrian signal device does not provide street name information in audible format. (Street name information in one format or the other is required to be compliant.)	-	-	-	2005 PROWA G- R306.4.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
18	Highridge Rd. & Crest Rd.	04.24B - Vibrotactile Signal Device	A crosswalk with pedestrian signal indication does not have a vibrotactile signal device integrated into the signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
19	Crestridge Rd. & Crenshaw Blvd.	04.24A - Audible Signal Device	A crosswalk with pedestrian signal indication does not have an audible signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	A - Safety Hazard	1 - Access into Facilities (28 CFR 36.304(c)(1))
20	Crestridge Rd. & Crenshaw Blvd.	04.24B - Vibrotactile Signal Device	A crosswalk with pedestrian signal indication does not have a vibrotactile signal device integrated into the signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
21	Highridge Rd. & Crest Rd.	04.25 - Pedestrian Signal Device - Clear Floor Space	Location of pedestrian signal device does not accommodate a level 30" x 48" min.. clear space, centered and parallel to the pedestrian signal push button. (Accessible pedestrian signals shall be located so that the vibrotactile feature can be contacted from the level landing serving a curb ramp, if provided, or from a clear floor or ground space that is in line with the crosswalk line adjacent to the vehicle stop line.)	4.2.4	305.3; 305.3	1118B.4 item 1	2005 PROWA G- R306.2.1	5.1% CS & 2.9% RS.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))



City of Rancho Palos Verdes
Rancho Palos Verdes ADA Assessment
Compliance Report
Facility ID # Area 4 Pedestrian Signals



Reporting: 150 of 4367 Rclds

Author: Vaish, B

Group 04 - Curb Ramps

#	Location	Item Name	Description	1991 ADAAG	2004 ADAAG	2007 CBC	2005 PROWA	Existing Condition	Use	Severity	Location Type
22	Crestridge Rd. & Crenshaw Blvd.	04.32A - Push Button Operating Effort	The force required to activate operable part(s) of pedestrian signal device exceeds 5 lbs.	4.27.4	309.4	1117B.6 item 4	2005 PROWA G- R306.3.1; R405.4	6 LBF.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
23	Crestridge Rd. & Crenshaw Blvd.	04.32B - Push Button Locator Tone	The pedestrian signal push button does not incorporate a locator tone at the push button.	-	-	-	2005 PROWA G- R306.3.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
24	Crestridge Rd. & Crenshaw Blvd.	04.32C - Push Button Size	The pedestrian signal push button is not a min.. 2" across in one dimension.	-	-	-	2005 PROWA G- R306.3.3	1/2" diameter.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
25	Crestridge Rd. & Crenshaw Blvd.	04.33A - Directional Information and Signs	Pedestrian signal device does not provides compliant tactile or visual signs on the face of the device or its housing or mounting to indicate crosswalk direction and the name of the street containing the crosswalk served by the pedestrian signal.	4.30.4	703.1	1117B.5 .1 item 2; 1117B.5 .6	2005 PROWA G- R306.4		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
26	Crestridge Rd. & Crenshaw Blvd.	04.33B - Arrow	Pedestrian signal device does not includes a tactile arrow that contrasts with the background and is aligned parallel to the crosswalk direction.	-	-	-	2005 PROWA G- R306.4.1		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))



City of Rancho Palos Verdes
**Rancho Palos Verdes ADA Assessment
 Compliance Report**



Reporting: 150 of 4367 Rclds

Facility ID # Area 4 Pedestrian Signals

Author: Vaish, B

Group 04 - Curb Ramps

#	Location	Item Name	Description	1991 ADAAG	2004 ADAAG	2007 CBC	2005 PROWA	Existing Condition	Use	Severity	Location Type
27	Crestridge Rd. & Crenshaw Blvd.	04.33C - Street Name	Pedestrian signal device does not includes street name information consisting of California Grade 2 Braille and aligned parallel to the crosswalk direction. OR Pedestrian signal device does not provide street name information in audible format. (Street name information in one format or the other is required to be compliant.)	-	-	-	2005 PROWA G- R306.4.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
28	Highridge Rd. & Crest Rd.	04.32B - Push Button Locator Tone	The pedestrian signal push button does not incorporate a locator tone at the push button.	-	-	-	2005 PROWA G- R306.3.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
29	Crestridge Rd. & Crenshaw Blvd.	04.25 - Pedestrian Signal Device - Clear Floor Space	Location of pedestrian signal device does not accommodate a level 30" x 48" min.. clear space, centered and parallel to the pedestrian signal push button. (Accessible pedestrian signals shall be located so that the vibrotactile feature can be contacted from the level landing serving a curb ramp, if provided, or from a clear floor or ground space that is in line with the crosswalk line adjacent to the vehicle stop line.)	4.2.4	305.3; 305.3	1118B.4 item 1	2005 PROWA G- R306.2.1	2.4% RS.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
30	Crestridge Rd. & Crenshaw Blvd.	04.24A - Audible Signal Device	A crosswalk with pedestrian signal indication does not have an audible signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	A - Safety Hazard	1 - Access into Facilities (28 CFR 36.304(c)(1))
31	Crestridge Rd. & Crenshaw Blvd.	04.33A - Directional Information and Signs	Pedestrian signal device does not provides compliant tactile or visual signs on the face of the device or its housing or mounting to indicate crosswalk direction and the name of the street containing the crosswalk served by the pedestrian signal.	4.30.4	703.1	1117B.5 .1 item 2; 1117B.5 .6	2005 PROWA G- R306.4		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))



City of Rancho Palos Verdes
Rancho Palos Verdes ADA Assessment
Compliance Report



Reporting: 150 of 4367 Rcds

Facility ID # Area 4 Pedestrian Signals

Author: Vaish, B

Group 04 - Curb Ramps

#	Location	Item Name	Description	1991 ADAAG	2004 ADAAG	2007 CBC	2005 PROWA	Existing Condition	Use	Severity	Location Type
32	Crestridge Rd. & Crenshaw Blvd.	04.32C - Street Name	Pedestrian signal device does not includes street name information consisting of California Grade 2 Braille and aligned parallel to the crosswalk direction. OR Pedestrian signal device does not provide street name information in audible format. (Street name information in one format or the other is required to be compliant.)	-	-	-	2005 PROWA G- R306.4.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
33	Crestridge Rd. & Crenshaw Blvd.	04.32A - Push Button Operating Effort	The force required to activate operable part(s) of pedestrian signal device exceeds 5 lbs.	4.27.4	309.4	1117B.6 item 4	2005 PROWA G- R306.3.1; R405.4	6 LBF.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
34	Crestridge Rd. & Crenshaw Blvd.	04.24B - Vibrotactile Signal Device	A crosswalk with pedestrian signal indication does not have a vibrotactile signal device integrated into the signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
35	Crestridge Rd. & Crenshaw Blvd.	04.33B - Arrow	Pedestrian signal device does not includes a tactile arrow that contrasts with the background and is aligned parallel to the crosswalk direction.	-	-	-	2005 PROWA G- R306.4.1		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
36	Crestridge Rd. & Crenshaw Blvd.	04.25 - Pedestrian Signal Device - Clear Floor Space	Location of pedestrian signal device does not accommodate a level 30" x 48" min.. clear space, centered and parallel to the pedestrian signal push button. (Accessible pedestrian signals shall be located so that the vibrotactile feature can be contacted from the level landing serving a curb ramp, if provided, or from a clear floor or ground space that is in line with the crosswalk line adjacent to the vehicle stop line.)	4.2.4	305.3; Fig. 305.3	1118B.4 item 1	2005 PROWA G- R306.2.1	Stable surface is not provided.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))



City of Rancho Palos Verdes
Rancho Palos Verdes ADA Assessment
Compliance Report



Reporting: 150 of 4367 Rclds

Facility ID # Area 4 Pedestrian Signals

Author: Vaish, B

Group 04 - Curb Ramps

#	Location	Item Name	Description	1991 ADAAG	2004 ADAAG	2007 CBC	2005 PROWA	Existing Condition	Use	Severity	Location Type
37	Crestridge Rd. & Crenshaw Blvd.	04.32C - Push Button Size	The pedestrian signal push button is not a min.. 2" across in one dimension.	-	-	-	2005 PROWA G-R306.3.3	1/2" diameter.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
38	Crestridge Rd. & Crenshaw Blvd.	04.40 - Other - Curb Ramps and Pedestrian Crossings	See Additional Comments	-	-	-	-	Path of travel to pedestrian signal device is not provided.	PV - Public/Visitor Use	B - Severe or Complete Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
39	Crestridge Rd. & Crenshaw Blvd.	04.24A - Audible Signal Device	A crosswalk with pedestrian signal indication does not have an audible signal device to indicate the WALK interval.	-	-	-	2005 PROWA G-R306.2		PV - Public/Visitor Use	A - Safety Hazard	1 - Access into Facilities (28 CFR 36.304(c)(1))
40	Crestridge Rd. & Crenshaw Blvd.	04.24B - Vibrotactile Signal Device	A crosswalk with pedestrian signal indication does not have a vibrotactile signal device integrated into the signal device to indicate the WALK interval.	-	-	-	2005 PROWA G-R306.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
41	Crestridge Rd. & Crenshaw Blvd.	04.25 - Pedestrian Signal Device - Clear Floor Space	Location of pedestrian signal device does not accommodate a level 30" x 48" min.. clear space, centered and parallel to the pedestrian signal push button. (Accessible pedestrian signals shall be located so that the vibrotactile feature can be contacted from the level landing serving a curb ramp, if provided, or from a clear floor or ground space that is in line with the crosswalk line adjacent to the vehicle stop line.)	4.2.4	305.3; 305.3	1118B.4 item 1	2005 PROWA G-R306.2.1	9.4% CS & 5% RS.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))



City of Rancho Palos Verdes
Rancho Palos Verdes ADA Assessment
Compliance Report
Facility ID # Area 4 Pedestrian Signals



Reporting: 150 of 4367 Rcds

Author: Vaish, B

Group 04 - Curb Ramps

#	Location	Item Name	Description	1991 ADAAG	2004 ADAAG	2007 CBC	2005 PROWA	Existing Condition	Use	Severity	Location Type
42	Highridge Rd. & Crest Rd.	04.33A - Directional Information and Signs	Pedestrian signal device does not provides compliant tactile or visual signs on the face of the device or its housing or mounting to indicate crosswalk direction and the name of the street containing the crosswalk served by the pedestrian signal.	4.30.4	703.1	1117B.5 .1 item 2;	2005 PROWA G- R306.4	1117B.5 .6	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
43	Crestridge Rd. & Crenshaw Blvd.	04.32A - Push Button Operating Effort	The force required to activate operable part(s) of pedestrian signal device exceeds 5 lbs.	4.27.4	309.4	1117B.6 item 4	2005 PROWA G- R306.3.1; R405.4	6 LBF.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
44	Crestridge Rd. & Crenshaw Blvd.	04.32B - Push Button Locator Tone	The pedestrian signal push button does not incorporate a locator tone at the push button.	-	-	-	2005 PROWA G- R306.3.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
45	Crestridge Rd. & Crenshaw Blvd.	04.32C - Push Button Size	The pedestrian signal push button is not a min.. 2" across in one dimension.	-	-	-	2005 PROWA G- R306.3.3	1/2" diameter.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
46	Crestridge Rd. & Crenshaw Blvd.	04.33A - Directional Information and Signs	Pedestrian signal device does not provides compliant tactile or visual signs on the face of the device or its housing or mounting to indicate crosswalk direction and the name of the street containing the crosswalk served by the pedestrian signal.	4.30.4	703.1	1117B.5 .1 item 2;	2005 PROWA G- R306.4	1117B.5 .6	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))



City of Rancho Palos Verdes
Rancho Palos Verdes ADA Assessment
Compliance Report
Facility ID # Area 4 Pedestrian Signals



Reporting: 150 of 4367 Rcds

Author: Vaish, B

Group 04 - Curb Ramps

#	Location	Item Name	Description	1991 ADAAG	2004 ADAAG	2007 CBC	2005 PROWA	Existing Condition	Use	Severity	Location Type
47	Crestridge Rd. & Crenshaw Blvd.	04.33B - Arrow	Pedestrian signal device does not includes a tactile arrow that contrasts with the background and is aligned parallel to the crosswalk direction.	-	-	-	2005 PROWA G-R306.4.1		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
48	Crestridge Rd. & Crenshaw Blvd.	04.33C - Street Name	Pedestrian signal device does not includes street name information consisting of California Grade 2 Braille and aligned parallel to the crosswalk direction. OR Pedestrian signal device does not provide street name information in audible format. (Street name information in one format or the other is required to be compliant.)	-	-	-	2005 PROWA G-R306.4.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
49	Highridge Rd. & Crest Rd.	04.33B - Arrow	Pedestrian signal device does not includes a tactile arrow that contrasts with the background and is aligned parallel to the crosswalk direction.	-	-	-	2005 PROWA G-R306.4.1		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
50	Crestridge Rd. & Crenshaw Blvd.	04.24A - Audible Signal Device	A crosswalk with pedestrian signal indication does not have an audible signal device to indicate the WALK interval.	-	-	-	2005 PROWA G-R306.2		PV - Public/Visitor Use	A - Safety Hazard	1 - Access into Facilities (28 CFR 36.304(c)(1))
51	Crestridge Rd. & Crenshaw Blvd.	04.24B - Vibrotactile Signal Device	A crosswalk with pedestrian signal indication does not have a vibrotactile signal device integrated into the signal device to indicate the WALK interval.	-	-	-	2005 PROWA G-R306.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))



City of Rancho Palos Verdes
Rancho Palos Verdes ADA Assessment
Compliance Report



Reporting: 150 of 4367 Rclds

Facility ID # Area 4 Pedestrian Signals

Author: Vaish, B

Group 04 - Curb Ramps

#	Location	Item Name	Description	1991 ADAAG	2004 ADAAG	2007 CBC	2005 PROWA	Existing Condition	Use	Severity	Location Type
52	Crestridge Rd. & Crenshaw Blvd.	04.25 - Pedestrian Signal Device - Clear Floor Space	Location of pedestrian signal device does not accommodate a level 30" x 48" min.. clear space, centered and parallel to the pedestrian signal push button. (Accessible pedestrian signals shall be located so that the vibrotactile feature can be contacted from the level landing serving a curb ramp, if provided, or from a clear floor or ground space that is in line with the crosswalk line adjacent to the vehicle stop line.)	4.2.4	305.3; 305.3	1118B.4 item 1	2005 PROWA G- R306.2.1	10.5% CS.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
53	Highridge Rd. & Crest Rd.	04.33C - Street Name	Pedestrian signal device does not includes street name information consisting of California Grade 2 Braille and aligned parallel to the crosswalk direction. OR Pedestrian signal device does not provide street name information in audible format. (Street name information in one format or the other is required to be compliant.)	-	-	-	2005 PROWA G- R306.4.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
54	Crestridge Rd. & Crenshaw Blvd.	04.32A - Push Button Operating Effort	The force required to activate operable part(s) of pedestrian signal device exceeds 5 lbs.	4.27.4	309.4	1117B.6 item 4	2005 PROWA G- R306.3.1; R405.4		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
55	Crestridge Rd. & Crenshaw Blvd.	04.32B - Push Button Locator Tone	The pedestrian signal push button does not incorporate a locator tone at the push button.	-	-	-	2005 PROWA G- R306.3.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
56	Crestridge Rd. & Crenshaw Blvd.	04.32C - Push Button Size	The pedestrian signal push button is not a min.. 2" across in one dimension.	-	-	-	2005 PROWA G- R306.3.3	1/2" diameter.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))



City of Rancho Palos Verdes
Rancho Palos Verdes ADA Assessment
Compliance Report
Facility ID # Area 4 Pedestrian Signals



Reporting: 150 of 4367 Rcds

Author: Vaish, B

Group 04 - Curb Ramps

#	Location	Item Name	Description	1991 ADAAG	2004 ADAAG	2007 CBC	2005 PROWA	Existing Condition	Use	Severity	Location Type
57	Crestridge Rd. & Crenshaw Blvd.	04.33A - Directional Information and Signs	Pedestrian signal device does not provides compliant tactile or visual signs on the face of the device or its housing or mounting to indicate crosswalk direction and the name of the street containing the crosswalk served by the pedestrian signal.	4.30.4	703.1	1117B.5 .1 item 2;	2005 PROWA G- R306.4		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
58	Crestridge Rd. & Crenshaw Blvd.	04.33B - Arrow	Pedestrian signal device does not includes a tactile arrow that contrasts with the background and is aligned parallel to the crosswalk direction.	-	-	-	2005 PROWA G- R306.4.1		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
59	Crestridge Rd. & Crenshaw Blvd.	04.33C - Street Name	Pedestrian signal device does not includes street name information consisting of California Grade 2 Braille and aligned parallel to the crosswalk direction. OR Pedestrian signal device does not provide street name information in audible format. (Street name information in one format or the other is required to be compliant.)	-	-	-	2005 PROWA G- R306.4.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
60	Highridge Rd. & Crest Rd.	04.32A - Push Button Operating Effort	The force required to activate operable part(s) of pedestrian signal device exceeds 5 lbs.	4.27.4	309.4	1117B.6 item 4	2005 PROWA G- R306.3.1; R405.4	6 LBF.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
61	Crestridge Rd. & Crenshaw Blvd.	04.24A - Audible Signal Device	A crosswalk with pedestrian signal indication does not have an audible signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	A - Safety Hazard	1 - Access into Facilities (28 CFR 36.304(c)(1))



City of Rancho Palos Verdes
Rancho Palos Verdes ADA Assessment
Compliance Report



Reporting: 150 of 4367 Rclds

Facility ID # Area 4 Pedestrian Signals

Author: Vaish, B

Group 04 - Curb Ramps

#	Location	Item Name	Description	1991 ADAAG	2004 ADAAG	2007 CBC	2005 PROWA	Existing Condition	Use	Severity	Location Type
62	Crestridge Rd. & Crenshaw Blvd.	04.33A - Directional Information and Signs	Pedestrian signal device does not provides compliant tactile or visual signs on the face of the device or its housing or mounting to indicate crosswalk direction and the name of the street containing the crosswalk served by the pedestrian signal.	4.30.4	703.1	1117B.5 .1 item 2;	2005 PROWA G- R306.4		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
63	Crestridge Rd. & Crenshaw Blvd.	04.40 - Other - Curb Ramps and Pedestrian Crossings	See Additional Comments	-	-	-	-	Path of travel to pedestrian signal device is not provided.	PV - Public/Visitor Use	B - Severe or Complete Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
64	Crestridge Rd. & Crenshaw Blvd.	04.24B - Vibrotactile Signal Device	A crosswalk with pedestrian signal indication does not have a vibrotactile signal device integrated into the signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
65	Crestridge Rd. & Crenshaw Blvd.	04.33B - Arrow	Pedestrian signal device does not includes a tactile arrow that contrasts with the background and is aligned parallel to the crosswalk direction.	-	-	-	2005 PROWA G- R306.4.1		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
66	Crestridge Rd. & Crenshaw Blvd.	04.25 - Pedestrian Signal Device - Clear Floor Space	Location of pedestrian signal device does not accommodate a level 30" x 48" min.. clear space, centered and parallel to the pedestrian signal push button. (Accessible pedestrian signals shall be located so that the vibrotactile feature can be contacted from the level landing serving a curb ramp, if provided, or from a clear floor or ground space that is in line with the crosswalk line adjacent to the vehicle stop line.)	4.2.4	305.3; 305.3	1118B.4 item 1	2005 PROWA G- R306.2.1	10% CS & 5.2% RS.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))



City of Rancho Palos Verdes
Rancho Palos Verdes ADA Assessment
Compliance Report
Facility ID # Area 4 Pedestrian Signals



Reporting: 150 of 4367 Rcds

Author: Vaish, B

Group 04 - Curb Ramps

#	Location	Item Name	Description	1991 ADAAG	2004 ADAAG	2007 CBC	2005 PROWA Condition	Use	Severity	Location Type
67	Crestridge Rd. & Crenshaw Blvd.	04.32B - Push Button Locator Tone	The pedestrian signal push button does not incorporate a locator tone at the push button.	-	-	-	2005 PROWA G- R306.3.2	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
68	Crestridge Rd. & Crenshaw Blvd.	04.33C - Street Name	Pedestrian signal device does not includes street name information consisting of California Grade 2 Braille and aligned parallel to the crosswalk direction. OR Pedestrian signal device does not provide street name information in audible format. (Street name information in one format or the other is required to be compliant.)	-	-	-	2005 PROWA G- R306.4.2	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
69	Highridge Rd. & Crest Rd.	04.24A - Audible Signal Device	A crosswalk with pedestrian signal indication does not have an audible signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2	PV - Public/Visitor Use	A - Safety Hazard	1 - Access into Facilities (28 CFR 36.304(c)(1))
70	Crestridge Rd. & Crenshaw Blvd.	04.24A - Audible Signal Device	A crosswalk with pedestrian signal indication does not have an audible signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2	PV - Public/Visitor Use	A - Safety Hazard	1 - Access into Facilities (28 CFR 36.304(c)(1))
71	Crestridge Rd. & Crenshaw Blvd.	04.24B - Vibrotactile Signal Device	A crosswalk with pedestrian signal indication does not have a vibrotactile signal device integrated into the signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
72	Highridge Rd. & Crest Rd.	04.24B - Vibrotactile Signal Device	A crosswalk with pedestrian signal indication does not have a vibrotactile signal device integrated into the signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))



City of Rancho Palos Verdes
Rancho Palos Verdes ADA Assessment
Compliance Report
Facility ID # Area 4 Pedestrian Signals



Reporting: 150 of 4367 Rclds

Author: Vaish, B

Group 04 - Curb Ramps

#	Location	Item Name	Description	1991 ADAAG	2004 ADAAG	2007 CBC	2005 PROWA	Existing Condition	Use	Severity	Location Type
73	Crestridge Rd. & Crenshaw Blvd.	04.32A - Push Button Operating Effort	The force required to activate operable part(s) of pedestrian signal device exceeds 5 lbs.	4.27.4	309.4	1117B.6 item 4	2005 PROWA G- R306.3.1; R405.4	7 LBF.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
74	Crestridge Rd. & Crenshaw Blvd.	04.32B - Push Button Locator Tone	The pedestrian signal push button does not incorporate a locator tone at the push button.	-	-	-	2005 PROWA G- R306.3.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
75	Crestridge Rd. & Crenshaw Blvd.	04.33A - Directional Information and Signs	Pedestrian signal device does not provides compliant tactile or visual signs on the face of the device or its housing or mounting to indicate crosswalk direction and the name of the street containing the crosswalk served by the pedestrian signal.	4.30.4	703.1	1117B.5 .1 item 2; 1117B.5 .6	2005 PROWA G- R306.4		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
76	Crestridge Rd. & Crenshaw Blvd.	04.33B - Arrow	Pedestrian signal device does not includes a tactile arrow that contrasts with the background and is aligned parallel to the crosswalk direction.	-	-	-	2005 PROWA G- R306.4.1		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
77	Crestridge Rd. & Crenshaw Blvd.	04.33C - Street Name	Pedestrian signal device does not includes street name information consisting of California Grade 2 Braille and aligned parallel to the crosswalk direction. OR Pedestrian signal device does not provide street name information in audible format. (Street name information in one format or the other is required to be compliant.)	-	-	-	2005 PROWA G- R306.4.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))



City of Rancho Palos Verdes
Rancho Palos Verdes ADA Assessment
Compliance Report



Reporting: 150 of 4367 Rcds

Facility ID # Area 4 Pedestrian Signals

Author: Vaish, B

Group 04 - Curb Ramps

#	Location	Item Name	Description	1991 ADAAG	2004 ADAAG	2007 CBC	2005 PROWA	Existing Condition	Use	Severity	Location Type
78	Highridge Rd. & Crest Rd.	04.25 - Pedestrian Signal Device - Clear Floor Space	Location of pedestrian signal device does not accommodate a level 30" x 48" min.. clear space, centered and parallel to the pedestrian signal push button. (Accessible pedestrian signals shall be located so that the vibrotactile feature can be contacted from the level landing serving a curb ramp, if provided, or from a clear floor or ground space that is in line with the crosswalk line adjacent to the vehicle stop line.)	4.2.4	305.3; Fig. 305.3	1118B.4 item 1	2005 PROWA G-	3.1% CS & 5.6% RS. R306.2.1	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
79	Crestridge Rd. & Crenshaw Blvd.	04.25 - Pedestrian Signal Device - Clear Floor Space	Location of pedestrian signal device does not accommodate a level 30" x 48" min.. clear space, centered and parallel to the pedestrian signal push button. (Accessible pedestrian signals shall be located so that the vibrotactile feature can be contacted from the level landing serving a curb ramp, if provided, or from a clear floor or ground space that is in line with the crosswalk line adjacent to the vehicle stop line.)	4.2.4	305.3; Fig. 305.3	1118B.4 item 1	2005 PROWA G-	7.7% CS & 2.1% RS. R306.2.1	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
80	Crestridge Rd. & Crenshaw Blvd.	04.24A - Audible Signal Device	A crosswalk with pedestrian signal indication does not have an audible signal device to indicate the WALK interval.	-	-	-	2005 PROWA G-	R306.2	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
81	Crestridge Rd. & Crenshaw Blvd.	04.24B - Vibrotactile Signal Device	A crosswalk with pedestrian signal indication does not have a vibrotactile signal device integrated into the signal device to indicate the WALK interval.	-	-	-	2005 PROWA G-	R306.2	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
82	Highridge Rd. & Crest Rd.	04.32B - Push Button Locator Tone	The pedestrian signal push button does not incorporate a locator tone at the push button.	-	-	-	2005 PROWA G-	R306.3.2	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))



City of Rancho Palos Verdes
Rancho Palos Verdes ADA Assessment
Compliance Report
Facility ID # Area 4 Pedestrian Signals



Reporting: 150 of 4367 Rclds

Author: Vaish, B

Group 04 - Curb Ramps

#	Location	Item Name	Description	1991 ADAAG	2004 ADAAG	2007 CBC	2005 PROWA	Existing Condition	Use	Severity	Location Type
83	Crestridge Rd. & Crenshaw Blvd.	04.32A - Push Button Operating Effort	The force required to activate operable part(s) of pedestrian signal device exceeds 5 lbs.	4.27.4	309.4	1117B.6 item 4	2005 PROWA G- R306.3.1; R405.4	8 LBF.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
84	Crestridge Rd. & Crenshaw Blvd.	04.32B - Push Button Locator Tone	The pedestrian signal push button does not incorporate a locator tone at the push button.	-	-	-	2005 PROWA G- R306.3.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
85	Crestridge Rd. & Crenshaw Blvd.	04.32C - Push Button Size	The pedestrian signal push button is not a min.. 2" across in one dimension.	-	-	-	2005 PROWA G- R306.3.3	1/2" diameter.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
86	Crestridge Rd. & Crenshaw Blvd.	04.33A - Directional Information and Signs	Pedestrian signal device does not provides compliant tactile or visual signs on the face of the device or its housing or mounting to indicate crosswalk direction and the name of the street containing the crosswalk served by the pedestrian signal.	4.30.4	703.1	1117B.5 .1 item 2; 1117B.5 .6	2005 PROWA G- R306.4		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
87	Crestridge Rd. & Crenshaw Blvd.	04.33B - Arrow	Pedestrian signal device does not includes a tactile arrow that contrasts with the background and is aligned parallel to the crosswalk direction.	-	-	-	2005 PROWA G- R306.4.1		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))



City of Rancho Palos Verdes
**Rancho Palos Verdes ADA Assessment
 Compliance Report**



Reporting: 150 of 4367 Rclds

Facility ID # Area 4 Pedestrian Signals

Author: Vaish, B

Group 04 - Curb Ramps

#	Location	Item Name	Description	1991 ADAAG	2004 ADAAG	2007 CBC	2005 PROWA	Existing Condition	Use	Severity	Location Type
88	Crestridge Rd. & Crenshaw Blvd.	04.33C - Street Name	Pedestrian signal device does not includes street name information consisting of California Grade 2 Braille and aligned parallel to the crosswalk direction. OR Pedestrian signal device does not provide street name information in audible format. (Street name information in one format or the other is required to be compliant.)	-	-	-	2005 PROWA G-R306.4.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
89	Highridge Rd. & Crest Rd.	04.32C - Push Button Size	The pedestrian signal push button is not a min.. 2" across in one dimension.	-	-	-	2005 PROWA G-R306.3.3	1/2" diameter.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
90	Crestridge Rd. & Crenshaw Blvd.	04.24A - Audible Signal Device	A crosswalk with pedestrian signal indication does not have an audible signal device to indicate the WALK interval.	-	-	-	2005 PROWA G-R306.2		PV - Public/Visitor Use	A - Safety Hazard	1 - Access into Facilities (28 CFR 36.304(c)(1))
91	Crestridge Rd. & Crenshaw Blvd.	04.24B - Vibrotactile Signal Device	A crosswalk with pedestrian signal indication does not have a vibrotactile signal device integrated into the signal device to indicate the WALK interval.	-	-	-	2005 PROWA G-R306.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
92	Crestridge Rd. & Crenshaw Blvd.	04.25 - Pedestrian Signal Device - Clear Floor Space	Location of pedestrian signal device does not accommodate a level 30" x 48" min.. clear space, centered and parallel to the pedestrian signal push button. (Accessible pedestrian signals shall be located so that the vibrotactile feature can be contacted from the level landing serving a curb ramp, if provided, or from a clear floor or ground space that is in line with the crosswalk line adjacent to the vehicle stop line.)	4.2.4	305.3; 305.3	1118B.4 item 1	2005 PROWA G-R306.2.1	15.5% CS.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))



City of Rancho Palos Verdes
Rancho Palos Verdes ADA Assessment
Compliance Report



Reporting: 150 of 4367 Rcds

Facility ID # Area 4 Pedestrian Signals

Author: Vaish, B

Group 04 - Curb Ramps

#	Location	Item Name	Description	1991 ADAAG	2004 ADAAG	2007 CBC	2005 PROWA	Existing Condition	Use	Severity	Location Type
93	Crestridge Rd. & Crenshaw Blvd.	04.32C - Push Button Size	The pedestrian signal push button is not a min.. 2" across in one dimension.	-	-	-	2005 PROWA G- R306.3.3	1/2" diameter.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
94	Crestridge Rd. & Crenshaw Blvd.	04.33A - Directional Information and Signs	Pedestrian signal device does not provides compliant tactile or visual signs on the face of the device or its housing or mounting to indicate crosswalk direction and the name of the street containing the crosswalk served by the pedestrian signal.	4.30.4	703.1	1117B.5 .1 item 2;	2005 PROWA G- R306.4 .6		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
95	Crestridge Rd. & Crenshaw Blvd.	04.33B - Arrow	Pedestrian signal device does not includes a tactile arrow that contrasts with the background and is aligned parallel to the crosswalk direction.	-	-	-	2005 PROWA G- R306.4.1		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
96	Crestridge Rd. & Crenshaw Blvd.	04.32A - Push Button Operating Effort	The force required to activate operable part(s) of pedestrian signal device exceeds 5 lbs.	4.27.4	309.4	1117B.6 item 4	2005 PROWA G- R306.3.1; R405.4	6 LBF.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
97	Crestridge Rd. & Crenshaw Blvd.	04.33C - Street Name	Pedestrian signal device does not includes street name information consisting of California Grade 2 Braille and aligned parallel to the crosswalk direction. OR Pedestrian signal device does not provide street name information in audible format. (Street name information in one format or the other is required to be compliant.)	-	-	-	2005 PROWA G- R306.4.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))



City of Rancho Palos Verdes
Rancho Palos Verdes ADA Assessment
Compliance Report



Reporting: 150 of 4367 Rcds

Facility ID # Area 4 Pedestrian Signals

Author: Vaish, B

Group 04 - Curb Ramps

#	Location	Item Name	Description	1991 ADAAG	2004 ADAAG	2007 CBC	2005 PROWA	Existing Condition	Use	Severity	Location Type
98	Highridge Rd. & Crest Rd.	04.33A - Directional Information and Signs	Pedestrian signal device does not provides compliant tactile or visual signs on the face of the device or its housing or mounting to indicate crosswalk direction and the name of the street containing the crosswalk served by the pedestrian signal.	4.30.4	703.1	1117B.5 .1 item 2;	2005 PROWA G- R306.4		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
99	Crestridge Rd. & Crenshaw Blvd.	04.24A - Audible Signal Device	A crosswalk with pedestrian signal indication does not have an audible signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
100	Crestridge Rd. & Crenshaw Blvd.	04.24B - Vibrotactile Signal Device	A crosswalk with pedestrian signal indication does not have a vibrotactile signal device integrated into the signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
101	Crestridge Rd. & Crenshaw Blvd.	04.25 - Pedestrian Signal Device - Clear Floor Space	Location of pedestrian signal device does not accommodate a level 30" x 48" min.. clear space, centered and parallel to the pedestrian signal push button. (Accessible pedestrian signals shall be located so that the vibrotactile feature can be contacted from the level landing serving a curb ramp, if provided, or from a clear floor or ground space that is in line with the crosswalk line adjacent to the vehicle stop line.)	4.2.4	305.3;	1118B.4 item 1	2005 PROWA G- R306.2. 1	3.4% CS & 11.7% RS.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
102	Highridge Rd. & Crest Rd.	04.33B - Arrow	Pedestrian signal device does not includes a tactile arrow that contrasts with the background and is aligned parallel to the crosswalk direction.	-	-	-	2005 PROWA G- R306.4. 1		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))



City of Rancho Palos Verdes
Rancho Palos Verdes ADA Assessment
Compliance Report
Facility ID # Area 4 Pedestrian Signals



Reporting: 150 of 4367 Rclds

Author: Vaish, B

Group 04 - Curb Ramps

#	Location	Item Name	Description	1991 ADAAG	2004 ADAAG	2007 CBC	2005 PROWA	Existing Condition	Use	Severity	Location Type
103	Crestridge Rd. & Crenshaw Blvd.	04.32B - Push Button Locator Tone	The pedestrian signal push button does not incorporate a locator tone at the push button.	-	-	-	2005 PROWA G- R306.3.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
104	Crestridge Rd. & Crenshaw Blvd.	04.32A - Push Button Operating Effort	The force required to activate operable part(s) of pedestrian signal device exceeds 5 lbs.	4.27.4	309.4	1117B.6 item 4	2005 PROWA G- R306.3.1; R405.4		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
105	Crestridge Rd. & Crenshaw Blvd.	04.33B - Arrow	Pedestrian signal device does not includes a tactile arrow that contrasts with the background and is aligned parallel to the crosswalk direction.	-	-	-	2005 PROWA G- R306.4.1		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
106	Crestridge Rd. & Crenshaw Blvd.	04.32C - Push Button Size	The pedestrian signal push button is not a min.. 2" across in one dimension.	-	-	-	2005 PROWA G- R306.3.3	1/2" diameter.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
107	Highridge Rd. & Crest Rd.	04.33C - Street Name	Pedestrian signal device does not includes street name information consisting of California Grade 2 Braille and aligned parallel to the crosswalk direction. OR Pedestrian signal device does not provide street name information in audible format. (Street name information in one format or the other is required to be compliant.)	-	-	-	2005 PROWA G- R306.4.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
108	Highridge Rd. & Crest Rd.	04.24A - Audible Signal Device	A crosswalk with pedestrian signal indication does not have an audible signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	A - Safety Hazard	1 - Access into Facilities (28 CFR 36.304(c)(1))



City of Rancho Palos Verdes
Rancho Palos Verdes ADA Assessment
Compliance Report



Reporting: 150 of 4367 Rcds

Facility ID # Area 4 Pedestrian Signals

Author: Vaish, B

Group 04 - Curb Ramps

#	Location	Item Name	Description	1991 ADAAG	2004 ADAAG	2007 CBC	2005 PROWA	Existing Condition	Use	Severity	Location Type
109	Highridge Rd. & Crest Rd.	04.24B - Vibrotactile Signal Device	A crosswalk with pedestrian signal indication does not have a vibrotactile signal device integrated into the signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
110	Highridge Rd. & Crest Rd.	04.25 - Pedestrian Signal Device - Clear Floor Space	Location of pedestrian signal device does not accommodate a level 30" x 48" min.. clear space, centered and parallel to the pedestrian signal push button. (Accessible pedestrian signals shall be located so that the vibrotactile feature can be contacted from the level landing serving a curb ramp, if provided, or from a clear floor or ground space that is in line with the crosswalk line adjacent to the vehicle stop line.)	4.2.4	305.3; 305.3	1118B.4 item 1	2005 PROWA G- R306.2.1	5.5% CS & 7.3% RS.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
111	Highridge Rd. & Crest Rd.	04.24A - Audible Signal Device	A crosswalk with pedestrian signal indication does not have an audible signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	A - Safety Hazard	1 - Access into Facilities (28 CFR 36.304(c)(1))
112	Highridge Rd. & Crest Rd.	04.32B - Push Button Locator Tone	The pedestrian signal push button does not incorporate a locator tone at the push button.	-	-	-	2005 PROWA G- R306.3.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
113	Highridge Rd. & Crest Rd.	04.33A - Directional Information and Signs	Pedestrian signal device does not provides compliant tactile or visual signs on the face of the device or its housing or mounting to indicate crosswalk direction and the name of the street containing the crosswalk served by the pedestrian signal.	4.30.4	703.1	1117B.5 .1 item 2; 1117B.5 .6	2005 PROWA G- R306.4		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))



City of Rancho Palos Verdes
Rancho Palos Verdes ADA Assessment
Compliance Report



Reporting: 150 of 4367 Rcds

Facility ID # Area 4 Pedestrian Signals

Author: Vaish, B

Group 04 - Curb Ramps

#	Location	Item Name	Description	1991 ADAAG	2004 ADAAG	2007 CBC	2005 PROWA	Existing Condition	Use	Severity	Location Type
114	Highridge Rd. & Crest Rd.	04.33B - Arrow	Pedestrian signal device does not includes a tactile arrow that contrasts with the background and is aligned parallel to the crosswalk direction.	-	-	-	2005 PROWA G- R306.4.1		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
115	Highridge Rd. & Crest Rd.	04.33C - Street Name	Pedestrian signal device does not includes street name information consisting of California Grade 2 Braille and aligned parallel to the crosswalk direction. OR Pedestrian signal device does not provide street name information in audible format. (Street name information in one format or the other is required to be compliant.)	-	-	-	2005 PROWA G- R306.4.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
116	Highridge Rd. & Crest Rd.	04.24B - Vibrotactile Signal Device	A crosswalk with pedestrian signal indication does not have a vibrotactile signal device integrated into the signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
117	Highridge Rd. & Crest Rd.	04.24A - Audible Signal Device	A crosswalk with pedestrian signal indication does not have an audible signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	A - Safety Hazard	1 - Access into Facilities (28 CFR 36.304(c)(1))
118	Highridge Rd. & Crest Rd.	04.24B - Vibrotactile Signal Device	A crosswalk with pedestrian signal indication does not have a vibrotactile signal device integrated into the signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))



City of Rancho Palos Verdes
Rancho Palos Verdes ADA Assessment
Compliance Report



Reporting: 150 of 4367 Rclds

Facility ID # Area 4 Pedestrian Signals

Author: Vaish, B

Group 04 - Curb Ramps

#	Location	Item Name	Description	1991 ADAAG	2004 ADAAG	2007 CBC	2005 PROWA	Existing Condition	Use	Severity	Location Type
119	Highridge Rd. & Crest Rd.	04.25 - Pedestrian Signal Device - Clear Floor Space	Location of pedestrian signal device does not accommodate a level 30" x 48" min.. clear space, centered and parallel to the pedestrian signal push button. (Accessible pedestrian signals shall be located so that the vibrotactile feature can be contacted from the level landing serving a curb ramp, if provided, or from a clear floor or ground space that is in line with the crosswalk line adjacent to the vehicle stop line.)	4.2.4	305.3; 305.3	1118B.4 item 1	2005 PROWA G- R306.2.1	7% CS.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
120	Highridge Rd. & Crest Rd.	04.32B - Push Button Locator Tone	The pedestrian signal push button does not incorporate a locator tone at the push button.	-	-	-	2005 PROWA G- R306.3.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
121	Highridge Rd. & Crest Rd.	04.33A - Directional Information and Signs	Pedestrian signal device does not provides compliant tactile or visual signs on the face of the device or its housing or mounting to indicate crosswalk direction and the name of the street containing the crosswalk served by the pedestrian signal.	4.30.4	703.1	1117B.5 .1 item 2; 1117B.5 .6	2005 PROWA G- R306.4		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
122	Highridge Rd. & Crest Rd.	04.33B - Arrow	Pedestrian signal device does not includes a tactile arrow that contrasts with the background and is aligned parallel to the crosswalk direction.	-	-	-	2005 PROWA G- R306.4.1		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
123	Highridge Rd. & Crest Rd.	04.33C - Street Name	Pedestrian signal device does not includes street name information consisting of California Grade 2 Braille and aligned parallel to the crosswalk direction. OR Pedestrian signal device does not provide street name information in audible format. (Street name information in one format or the other is required to be compliant.)	-	-	-	2005 PROWA G- R306.4.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))



City of Rancho Palos Verdes
Rancho Palos Verdes ADA Assessment
Compliance Report



Reporting: 150 of 4367 Rcds

Facility ID # Area 4 Pedestrian Signals

Author: Vaish, B

Group 04 - Curb Ramps

#	Location	Item Name	Description	1991 ADAAG	2004 ADAAG	2007 CBC	2005 PROWA	Existing Condition	Use	Severity	Location Type
124	Highridge Rd. & Crest Rd.	04.25 - Pedestrian Signal Device - Clear Floor Space	Location of pedestrian signal device does not accommodate a level 30" x 48" min.. clear space, centered and parallel to the pedestrian signal push button. (Accessible pedestrian signals shall be located so that the vibrotactile feature can be contacted from the level landing serving a curb ramp, if provided, or from a clear floor or ground space that is in line with the crosswalk line adjacent to the vehicle stop line.)	4.2.4	305.3; Fig. 305.3	1118B.4 item 1	2005 PROWA G- R306.2.1	3.5% CS & 8.8% RS.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
125	Highridge Rd. & Crest Rd.	04.32B - Push Button Locator Tone	The pedestrian signal push button does not incorporate a locator tone at the push button.	-	-	-	2005 PROWA G- R306.3.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
126	Highridge Rd. & Crest Rd.	04.24A - Audible Signal Device	A crosswalk with pedestrian signal indication does not have an audible signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2	33.759028,-118.379796	PV - Public/Visitor Use	A - Safety Hazard	1 - Access into Facilities (28 CFR 36.304(c)(1))
127	Highridge Rd. & Crest Rd.	04.24B - Vibrotactile Signal Device	A crosswalk with pedestrian signal indication does not have a vibrotactile signal device integrated into the signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
128	Highridge Rd. & Crest Rd.	04.25 - Pedestrian Signal Device - Clear Floor Space	Location of pedestrian signal device does not accommodate a level 30" x 48" min.. clear space, centered and parallel to the pedestrian signal push button. (Accessible pedestrian signals shall be located so that the vibrotactile feature can be contacted from the level landing serving a curb ramp, if provided, or from a clear floor or ground space that is in line with the crosswalk line adjacent to the vehicle stop line.)	4.2.4	305.3; Fig. 305.3	1118B.4 item 1	2005 PROWA G- R306.2.1	10.2% CS.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))



City of Rancho Palos Verdes
Rancho Palos Verdes ADA Assessment
Compliance Report
Facility ID # Area 4 Pedestrian Signals



Reporting: 150 of 4367 Rcds

Author: Vaish, B

Group 04 - Curb Ramps

#	Location	Item Name	Description	1991 ADAAG	2004 ADAAG	2007 CBC	2005 PROWA	Existing Condition	Use	Severity	Location Type
129	Highridge Rd. & Crest Rd.	04.26B1 - Pedestrian Signal Device - Location versus Curblines	Location of pedestrian signal device is not within 5' of curb.	-	-	-	2005 PROWA G- R306.2.1.1	7' from curb line.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
130	Highridge Rd. & Crest Rd.	04.33A - Directional Information and Signs	Pedestrian signal device does not provides compliant tactile or visual signs on the face of the device or its housing or mounting to indicate crosswalk direction and the name of the street containing the crosswalk served by the pedestrian signal.	4.30.4	703.1	1117B.5 .1 item 2;	2005 PROWA G- R306.4 .6		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
131	Highridge Rd. & Crest Rd.	04.32B - Push Button Locator Tone	The pedestrian signal push button does not incorporate a locator tone at the push button.	-	-	-	2005 PROWA G- R306.3.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
132	Highridge Rd. & Crest Rd.	04.33A - Directional Information and Signs	Pedestrian signal device does not provides compliant tactile or visual signs on the face of the device or its housing or mounting to indicate crosswalk direction and the name of the street containing the crosswalk served by the pedestrian signal.	4.30.4	703.1	1117B.5 .1 item 2;	2005 PROWA G- R306.4 .6		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
133	Highridge Rd. & Crest Rd.	04.33B - Arrow	Pedestrian signal device does not includes a tactile arrow that contrasts with the background and is aligned parallel to the crosswalk direction.	-	-	-	2005 PROWA G- R306.4.1		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))



City of Rancho Palos Verdes
Rancho Palos Verdes ADA Assessment
Compliance Report



Reporting: 150 of 4367 Rclds

Facility ID # Area 4 Pedestrian Signals

Author: Vaish, B

Group 04 - Curb Ramps

#	Location	Item Name	Description	1991 ADAAG	2004 ADAAG	2007 CBC	2005 PROWA	Existing Condition	Use	Severity	Location Type
134	Highridge Rd. & Crest Rd.	04.33C - Street Name	Pedestrian signal device does not includes street name information consisting of California Grade 2 Braille and aligned parallel to the crosswalk direction. OR Pedestrian signal device does not provide street name information in audible format. (Street name information in one format or the other is required to be compliant.)	-	-	-	2005 PROWA G- R306.4.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
135	Highridge Rd. & Crest Rd.	04.24A - Audible Signal Device	A crosswalk with pedestrian signal indication does not have an audible signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
136	Highridge Rd. & Crest Rd.	04.24B - Vibrotactile Signal Device	A crosswalk with pedestrian signal indication does not have a vibrotactile signal device integrated into the signal device to indicate the WALK interval.	-	-	-	2005 PROWA G- R306.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
137	Highridge Rd. & Crest Rd.	04.33B - Arrow	Pedestrian signal device does not includes a tactile arrow that contrasts with the background and is aligned parallel to the crosswalk direction.	-	-	-	2005 PROWA G- R306.4.1		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
138	Highridge Rd. & Crest Rd.	04.32B - Push Button Locator Tone	The pedestrian signal push button does not incorporate a locator tone at the push button.	-	-	-	2005 PROWA G- R306.3.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
139	Highridge Rd. & Crest Rd.	04.33A - Directional Information and Signs	Pedestrian signal device does not provides compliant tactile or visual signs on the face of the device or its housing or mounting to indicate crosswalk direction and the name of the street containing the crosswalk served by the pedestrian signal.	4.30.4	703.1	1117B.5 .1 item 2;	2005 PROWA G- R306.4 .6		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))



City of Rancho Palos Verdes
Rancho Palos Verdes ADA Assessment
Compliance Report



Reporting: 150 of 4367 Rcds

Facility ID # Area 4 Pedestrian Signals

Author: Vaish, B

Group 04 - Curb Ramps

#	Location	Item Name	Description	1991 ADAAG	2004 ADAAG	2007 CBC	2005 PROWA	Existing Condition	Use	Severity	Location Type
140	Highridge Rd. & Crest Rd.	04.33B - Arrow	Pedestrian signal device does not includes a tactile arrow that contrasts with the background and is aligned parallel to the crosswalk direction.	-	-	-	2005 PROWA G-R306.4.1		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
141	Highridge Rd. & Crest Rd.	04.33C - Street Name	Pedestrian signal device does not includes street name information consisting of California Grade 2 Braille and aligned parallel to the crosswalk direction. OR Pedestrian signal device does not provide street name information in audible format. (Street name information in one format or the other is required to be compliant.)	-	-	-	2005 PROWA G-R306.4.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
142	Highridge Rd. & Crest Rd.	04.24A - Audible Signal Device	A crosswalk with pedestrian signal indication does not have an audible signal device to indicate the WALK interval.	-	-	-	2005 PROWA G-R306.2		PV - Public/Visitor Use	A - Safety Hazard	1 - Access into Facilities (28 CFR 36.304(c)(1))
143	Highridge Rd. & Crest Rd.	04.24B - Vibrotactile Signal Device	A crosswalk with pedestrian signal indication does not have a vibrotactile signal device integrated into the signal device to indicate the WALK interval.	-	-	-	2005 PROWA G-R306.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
144	Highridge Rd. & Crest Rd.	04.25 - Pedestrian Signal Device - Clear Floor Space	Location of pedestrian signal device does not accommodate a level 30" x 48" min.. clear space, centered and parallel to the pedestrian signal push button. (Accessible pedestrian signals shall be located so that the vibrotactile feature can be contacted from the level landing serving a curb ramp, if provided, or from a clear floor or ground space that is in line with the crosswalk line adjacent to the vehicle stop line.)	4.2.4	305.3; 305.3	1118B.4 item 1	2005 PROWA G-R306.2.1	4.5% CS.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))



City of Rancho Palos Verdes
Rancho Palos Verdes ADA Assessment
Compliance Report
Facility ID # Area 4 Pedestrian Signals



Reporting: 150 of 4367 Rcds

Author: Vaish, B

Group 04 - Curb Ramps

#	Location	Item Name	Description	1991 ADAAG	2004 ADAAG	2007 CBC	2005 PROWA	Existing Condition	Use	Severity	Location Type
145	Highridge Rd. & Crest Rd.	04.26B1 - Pedestrian Signal Device - Location versus Curbline	Location of pedestrian signal device is not within 5' of curb.	-	-	-	2005 PROWA G-R306.2.1.1	6' from curb line.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
146	Highridge Rd. & Crest Rd.	04.33C - Street Name	Pedestrian signal device does not includes street name information consisting of California Grade 2 Braille and aligned parallel to the crosswalk direction. OR Pedestrian signal device does not provide street name information in audible format. (Street name information in one format or the other is required to be compliant.)	-	-	-	2005 PROWA G-R306.4.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
147	Highridge Rd. & Crest Rd.	04.32B - Push Button Locator Tone	The pedestrian signal push button does not incorporate a locator tone at the push button.	-	-	-	2005 PROWA G-R306.3.2		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
148	Highridge Rd. & Crest Rd.	04.32A - Push Button Operating Effort	The force required to activate operable part(s) of pedestrian signal device exceeds 5 lbs.	4.27.4	309.4	1117B.6 item 4	2005 PROWA G-R306.3.1; R405.4		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))
149	Highridge Rd. & Crest Rd.	04.33B - Arrow	Pedestrian signal device does not includes a tactile arrow that contrasts with the background and is aligned parallel to the crosswalk direction.	-	-	-	2005 PROWA G-R306.4.1		PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))



City of Rancho Palos Verdes
 Rancho Palos Verdes ADA Assessment
Compliance Report
 Facility ID # Area 4 Pedestrian Signals



Reporting: 150 of 4367 Rcds

Author: Vaish, B

Group 04 - Curb Ramps

#	Location	Item Name	Description	1991 ADAAG	2004 ADAAG	2007 CBC	2005 PROWA	Existing Condition	Use	Severity	Location Type
150	Highridge Rd. & Crest Rd.	04.32C - Push Button Size	The pedestrian signal push button is not a min.. 2" across in one dimension.	-	-	-	2005 PROWA G-R306.3.3	1/2" diameter.	PV - Public/Visitor Use	C - Partial Barrier to Access	1 - Access into Facilities (28 CFR 36.304(c)(1))

Number of Key Notes for Group 04 - Curb Ramps: 150

Number of Key Notes for Facility Area 4 Pedestrian Signals: 150

Total Number of Key Notes for All Groups: 150