



GENERAL NOTES - ELECTRICAL PLAN

1. 200 AMP LOAD CENTER; 120/240 SINGLE PHASE; 30 CIRCUIT PANEL.
2. TELEPHONE SERVICE BOARD - 3/4" PLYWOOD.
3. CONDUITS SIZED AS NOTED, BURIED 18" BELOW SUB GRADE.
4. 50W H.P. SODIUM INTERIOR QUALITY, LITHONIA #VR3-505-120-WP-LPI-RNP (OR APPROVED EQUAL).
5. 50W H.P. SODIUM EXTERIOR QUALITY, LITHONIA #JR2-505-4S-LP1-RNP-120 (OR APPROVED EQUAL), CONTROLLED BY CONTACTOR WITH PHOTO-CELL.
6. 8' FLUORESCENT, 2 LIGHT FIXTURES, LITHONIA #8T2 PR 240A (OR APPROVED EQUAL).
7. 100W INCANDESCENT LIGHT, LEVITON 9885 (OR APPROVED EQUAL).
8. 1500W STRIP HEATER, THERMOSTAT CONTROLLED, THERMADOR SL151A/SL-SUR (OR APPROVED EQUAL).
9. DUPLEX OUTLETS, INSTALLED TO MEET UBC, AND NEC STANDARDS.
10. DUPLEX OUTLETS WITH LOCKING COVERS P & S #WPH-8L, (OR APPROVED EQUAL) INSTALLED TO MEET UBC, AND NEC STANDARDS.
11. 30A 3 POLE LIGHTING CONTACTOR LOCATED IN STORAGE ROOM, CONTROLLED BY PHOTO-CELL FOR ALL EXTERIOR LIGHTING.
12. STANDARD LIGHT SWITCH.
13. PHOTO-CELL.
14. ALL EXTERIOR WIRING SHALL BE IN SCHEDULE 40 PVC CONDUITS. ALL INTERIOR WIRING SHALL BE IN EMT.
15. 4 CIRCUITS, 10A EACH SET IN LOCKING ENCLOSURE AT EDGE OF PARKING LOT (REFER TO PARKING LOT PLAN). SPECIFIC SITE OF ENCLOSURE TO BE FIELD APPROVED BY PROJECT ENGINEER.
16. 1 HIGH LEVEL ALARM INDICATOR LAMP FOR EACH GRINDER PUMP, ASSEMBLY FURNISHED ON WALL PLATE 2 3/4" x 4 1/2". LOCATION TO BE SITE VERIFIED & APPROVED BY PROJECT ENGINEER. INSTALLATION SHALL MEET UBC, AND NEC STANDARDS.
17. GRINDER PUMP ASSEMBLY SHALL REQUIRE 4 DEDICATED CIRCUITS; 1 10A DEDICATED CIRCUIT FOR EACH HIGH LEVEL ALARM INDICATOR LAMP, AND 1 15A DEDICATED CIRCUIT FOR EACH PUMP.
18. 1 15A DEDICATED CIRCUIT FOR PARKING LOT CONTROL SYSTEM.

ELECTRICAL PLAN 1/4" CONDUIT, END TO BE SITE APPROVED FOR PARKING LOT CONTROL SYSTEM.

<small>ISSUANCE OF THIS DRAWING FOR APPROVAL DOES NOT CONSTITUTE ACCEPTANCE OF CUSTOMER'S ORDER BY SUPER SECUR MFG. CO. THIS DRAWING TO BE USED IN PLACING MATERIALS SOLD UNDER THIS CONTRACT ONLY. PURCHASER TO CHECK ALL DIMENSIONS AT JOB AS SUPER SECUR MFG. CO. ASSUMES NO RESPONSIBILITY FOR FOUNDATIONS, SLAB, CONCRETE CURBS OR GENERAL BUILDING DIMENSIONS.</small>		MP-2325-0 22'-6" x 25'-0" SERIES 3 BUILDING w/CONCESSION / OFFICE & STORAGE	
SUPER SECUR MFG. CO. A DIVISION OF ACORN ENGINEERING COMPANY Sales: 1196 Evans Avenue (415) 824-1778 San Francisco, CA 94124 Factory: 15068 Proctor Avenue (818) 336-4561 City of Industry, CA 91744		ABALONE COVE, RANCHO PALOS VERDES, CALIFORNIA	
		DATE _____	DWN BY _____