Irrigation Plan
Vanderlip Park

Seacove Drive

#6 Don't exist
#1 & 7 must be 20 min.

Scale 1"=15'-0"

Irrigation List

SYMBOL	MODEL NO.	DESCRIPTION	GPM	PSI	REMARKS
○	ARNEN	4" POP-UP SPRINKLER	4.4	40	6" Pop. Nozzle
○	ARNEN	FULL CIRCLE	4.4	40	" "
○	ARNEN	HALF FULL CIRCLE	4.4	40	" "
○	ARNEN	QUARTER, HALF CIRCLE	1.8	20	ETD. NOZZLE FOR TREES LOCATED IN RECOMMENDED GRANITE
⊕	RAINBIRD	FULL CIRCLE BUBBLER		10	SEE NOTES
⊠	RAINBIRD	1" ANTI-TI ANTI-SIPHON VALVE			INSTALL PER LOCAL CODE
▷	RAINBIRD	1" DOUBLE CHECK BACKFLOW PREVENTER			PEDESTAL MOUNT
⋈		GATE VALVE			SIZE NOTED
═══		PVC SCH 40 MAIN LINE			1" MIN. 12"
═ ═ ═		PVC SCH 40 NON-PRESSURE			1" MIN. 18"
⊙		CONTROLLER (SEE PLAN FOR DETAILS)			SIZE AS REQ'D.

PRELIMINARY PLAN
SUBJECT TO CHANGE

Notes:

1. ALL INSTALLATION EQUIPMENT AND MATERIALS SHALL BE IN ACCORDANCE WITH LOCAL AGENCY REQUIREMENTS, CONTRACTOR SHALL OBTAIN ALL PERMITS AND PAY FEES.
2. SEE SPECIFICATIONS FOR FURTHER DETAILS.

Project No. Vanderlip Park
APPROVED BY CITY OF RANCHO PALOS VERDES
☐ with conditions ☐ as submitted
(refer to clearance form)
Date: 2-21-84 (EC)
Signature: J. Lightbourn
APPROVAL VOID AFTER 180 DAYS
*NOTICE: This is not valid unless accompanied by a completed clearance form.

RECEIVED
FEB 13 1984
ENVIRONMENTAL SERVICES

REVISIONS	BY
REDUCED PIPE TYPE	EH

Eugene Hirao, A.S.L.A.
Landscape Architecture
40 Racing Wind, Irvine, CA 92714
Tel No. (714) 845-8200

Vista Park, Rancho Palos Verdes
Tumanjan & Tumanjan Investments, Inc.
22939 Hawthorne Blvd., Torrance, CA.

DRAWN	
CHECKED	
DATE	
SCALE	
JOB NO.	
SHEET	L-2
OF	3 SHEETS

THESE PLANS ARE THE PROPERTY OF EUGENE HIRAO, A.S.L.A. AND ARE NOT TO BE USED IN WHOLE OR IN PART FOR ANY OTHER PROJECT WITHOUT THE WRITTEN PERMISSION OF EUGENE HIRAO, A.S.L.A.